

PROFORMA SAFE DRINKING WATER & SANITARY CERTIFICATE

No: 9554/23-12-25Dated: 23/12/25

It is certified that an Inspection team headed by Dy. Executive Engineer from **Rural Water Supply and Sanitation, Sub-Division, Nirmal, PHED** Inspected the **Vasavi World School, Thirumala Hills, Thimmapur Colony, Yellapelly Village, Nirmal Rural Mandal, Nirmal** on 23/12/25 and on the basis of Water Test Report (Attached) bearing No: 01

Dated: 23/12/25 of **GOVERNMENT OF TELANGANA WATER QUALITY MONITORING LABORATORY M.B INTRA SUB DIVISIONAL, NIRMAL** certified that Vasavi World School Safe Drinking Water Facility for the Students and Members of the Staff of the Institution. School also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central / State U.T. Government.

This Certificate is valid till 22-12-26.

To,
Vasavi World School,
Thirumala Hills, Vill: Thimmapur,
GP: Yellapelly, Mdl & Dist: Nirmal,
Telangana State – 504106


Dy Executive Engineer
RWS&S Sub-Divn. Nirmal
 Signature with Seal:

Name: M. Vinod Babu

Designation: Dy. Executive Engineer

Name & Address of the Office / Department:

Rural Water Supply and Sanitation,
Sub-Division, Nirmal 504106
Dist: Nirmal, Telangana State.

Note: This is certificate is issued by authorized officer / PHED lab / Local Bodies.

GOVERNMENT OF TELANGANA WATER QUALITY MONITORING LABORATORY M.B INTRA SUB DIVISION NIRMAL

REPORT ON CHEMICAL EXAMINATION OF DRINKING WATER

Date of Sample Collection 23.12.2025

Sl.No	Mandal	G.P.	Habitation	TEST	Type of Source	Turbidity (N.T.U.) Units	PH Value	Total Dissolved Solids (Mg/Lt)		Alkalinity (Mg/Lt)		Total Hardness (Mg/Lt)		Chloride (Mg/Lt)	Fluoride (Mg/Lt)	Nitrate (Mg/Lt) NO3	Sulphate (Mg/Lt)	Iron (Mg/Lt)	H2S Vails(Negative/positive)
								500	200	300	250	600	1000						
						<1	6.5 to 8.5	2000	600	600	300	250	1.0	1.5	45	200	0.3		
						No relaxation	8.01	345	184	180	62	0.5	6.5	35	0.06				
1	Nirmal	Nirmal	Nirmal	Vasavi World School(Near Entrance)	BW	0.1	7.54	452	220	240	92	0.7	5.5	21	0.12	Negative			
2	Nirmal	Nirmal	Nirmal	Vasavi World School(In Side School)	BW	0.3	8.01	345	184	180	62	0.5	6.5	35	0.06	Negative			

Water is potable and fit for drinking
Note:Standards as per Burea of Indian Standards I.S.10500-1991

Asst.Chemist
M.B.Intra Sub Division Nirmal

Assistant Executive Engineer
MB Intra, Nirmal Mandal